




# SHUBHRA

## ENTERPRISES



Ref No.:

Date :

### Certificate / Job Done Report

To,  
Jnana Prabodhini  
Near Hati Ganapati Mandir, Tilak Road,  
Pune.

Contact Name :- Prakash R  
Mobile :- 7040390191

This is to certified that below Fire Fighting System is in good and healthy condition.

#### Fire Fighting System Details

Wet Riser Down Comer	
Riser No. - 1	Qty
Booster Pump TRC Level	05 HP
Hose Reel Drum with 20mtr length flexible hose 19mmdia	6
Hdyrant Valve 63mmdia	7
Single Hose Box	7
Delivery Hose 15mtr length with 63mm dia	7
Branch Pipe	7
Fire Service Inlet	1
Starter for Booster level pump	1
Pendant Type Sprinkler Bulb	23
Fire Extinguisher	12

Riser No. - 2	Qty
Hose Reel Drum with 20mtr length flexible hose 19mmdia	5

**Note:-**

- \* Please check atleast once in a month that the needle in gauage is in **GREEN ZONE**.
- If it has fallen in to red zone, please inform us for immediate action.
- All system should be test in after every 15 days at your end or contract a AMC.

For Shubhra Enterprises  
Authorized Signatory